

CARTA DE TRAMITE

Para: Departamento de Educación
Dr. Eligio Hernández Pérez
Secretario de Educación

De: ROV Engineering Services PSC
100 Road 165 Suite 203 CIM Tower 1 Guaynabo, PR 00968
787-230-7171
Víctor M. Rodríguez Ortiz, P.E., CPIA, CPIU



Escuela: Juana Sánchez González

Código: (30734)

Municipio: Juncos

Fecha de:
Inspección 14-Jan-20

Nombre del Ingeniero que emite la recomendación: Ing. Carlos Rivera

Anejos:

1. Recomendación al Secretario.
2. Estampilla Digital Especial emitida por el CIAPR.
3. Informe de inspección Ocular.

OCULAR INSPECTION CHECKLIST

Where description is indicated, attach additional pages of notes and photographs keyed to appropriate checklist item.

A. GENERAL INFORMATION

1. Street Address of the School: Carr. 946 Km.0.9 Bo. Placita
2. City: Juncos State: Puerto Rico Zip: 00777
3. School Name: Juana Sanchez Gonzalez
4. Date of inspection: January 14 2020
5. Inspector's Name: Carlos N Rivera Rodriguez P.E.

B. BUILDING SITE INSPECTION

5. Utility Service Safety:

IMPORTANT—Immediately following an earthquake, check the entire property, especially near appliances, for the smell of gas. If gas odor is detected, turn off the gas at the meter where it enters the house. Locate and repair leaks before turning gas back on. If the gas odor persists after the gas has been shut off, vacate the building and contact the gas utility company immediately.

IMPORTANT—Before entering a damaged, vacant building verify that gas is off. Check the gas meter for damage and position of main gas valve, either a manual valve or a seismically-activated gas shut-off valve. Do not enter the building if gas odor is detected.

- a. Odor of natural gas leakage? YES NO b. Downed powerlines? YES NO

6. Surrounding topography: (check one)

- Flat
- Gently sloping (easily walkable)
- Steeply sloping (difficult or impossible to walk in some areas)

7. Building pad: (check one)

- Flat
- Terraced or multilevel
- Gently sloping (less than 4-foot ground surface elevation difference across house)
- Steeply sloping (greater than 4-foot ground surface elevation difference across house)

8. Geotechnical Issues: (if yes, provide description and photos)

	YES	NO
a. New cracks in the ground?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
b. Signs of fresh cracking in or movement of hardscape?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
c. Signs of fresh cracking in or movement of retaining walls?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
d. Patterns of cracking that extend through the ground surface, hardscape, and improvements?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
e. Evidence of sand boils or other fresh-appearing deposits of sand or mud?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
f. Unusual slumping, rising, or bulging of the ground surface?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
g. Evidence of rock falls or slope instability above site?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
h. Ground movement or wet areas indicating possible broken underground utility lines?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
i. Other phenomena (e.g., septic tanks surfacing, differential settlement, ground consolidation)?	<input type="checkbox"/>	<input checked="" type="checkbox"/>

OCULAR INSPECTION CHECKLIST

Where description is indicated, attach additional pages of notes and photographs keyed to appropriate checklist item.

B. BUILDING SITE INSPECTION (continued)

YES NO

9. Evidence of earthquake-induced permanent ground deformation in the immediate vicinity of the property?

C. GENERAL BUILDING INFORMATION

10. Safety Assessment Tag: (check one) None Green Yellow Red

(others): Yellow Red

11. a) Year of original construction (best estimate): 1970

b) Total square footage (best estimate): _____

YES NO

12. Have any repairs, modifications, or demolition been performed since the earthquake?

If yes, describe _____

13. Building configuration:

- a. Single story
- b. Combination one and two story
- c. Full two story
- d. Three story
- e. Split level
- f. Typical
- g. Other, describe _____

16. Sill bolting:

- a. Structure bolted to foundation
- b. Structure not bolted to foundation
- c. Don't know

14. Exterior wall finish:

- a. Stucco
- b. Panel siding
- c. Metal siding
- d. Masonry veneer
- e. Other, describe Cement Plaster

17. Roof configuration:

- a. Gable
- b. Hip
- c. Flat or very low slope
- d. Shed
- e. Other, describe _____

15. Foundation configuration:

- a. Slab-on-grade
- b. Crawl space without cripple walls
- c. Crawl space with cripple walls
- d. Exposed piers or posts
- e. Typical
- f. Metal
- g. Other, describe Not Available

18. Roof covering:

- a. Asphaltic membrane
- b. Wood shingle or shake
- c. Concrete
- d. Metal
- e. Elastomeric
- f. Other, describe _____

OCULAR INSPECTION CHECKLIST

Where description is indicated, attach additional pages of notes and photographs keyed to appropriate checklist item.

D. EXTERIOR BUILDING INSPECTION

	YES	NO	N/A
19. General: (if yes, provide description and photos)			
a. Collapse, partial collapse, or building off foundation?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
b. Obvious lean in any story?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
20. Exterior walls: (if yes, provide description and photos)			
a. Fresh cracking at corners of door and window openings?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
b. Fresh cracking at building corners?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
c. Door or window openings racked out of square?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
d. Broken glass in windows or doors?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
e. Wall leaning?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
f. Bulging or delamination of stucco?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
g. Pattern of cracking that extends from the ground surface, through foundation, and wall?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
h. Evidence of recent relative movement at mudsill line?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
i. At locations where the exterior stucco is continuous from the framing down over the foundation, is there cracking of stucco along the mudsill level accompanied by indications of permanent displacement (sliding) of the building relative to the foundation?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
j. Collapse, partial collapse, or separation of masonry veneer?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
k. Severe cracking, separations, or offsets at building irregularities?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
21. Foundation: (if yes, provide description and photos)			
a. Fresh cracking of exposed perimeter foundation?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
b. Relative movement between slab and footing in "two-pour" slab-on-grade foundations?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
c. Ask homeowner if any earthquake retrofits have been done to the home?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
If Y describe: _____			
d. If the answer to c is Y, were bolts added to connect the home to the foundation?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
e. If the answer to c is Y, were plywood or sheathing added to any cripple walls under the home?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

OCULAR INSPECTION CHECKLIST

Where description is indicated, attach additional pages of notes and photographs keyed to appropriate checklist item.

D. EXTERIOR BUILDING INSPECTION (continued)

		YES	NO	N/A
22. Kitchen Hook (if yes, provide description and photos)	a. Present on external wall?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
	b. Present at internal location?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
	c. Collapse or partial collapse?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
	d. Visible damage or cracking?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
	e. Visible tilting or separation from building?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
	f. Shifted or loose and displaced	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
	g. Deterioration or deformation	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
23. Roof: (if yes, provide description and photos)	a. Shifted or dislodged or concrete damage?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
	b. Impact damage to roof from falling object?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
	c. Displaced rooftop HVAC units?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
	d. Significantly sagging roof ridgelines?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
	e. Signs of movement between rafter tails and wall finishes at eaves?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
	f. Buckled/dislodged flashing or tearing of roof membrane, roof/wall intersections in split level buildings, additions, or other building irregularities?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
	g. Tearing of roof membrane or deck waterproofing at re-entrant corners?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
	h. Toppling, shifting, or damage/leakage at refrigerant and electrical lines of rooftop mechanical equipment?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
	i. Shifting of or damage to solar panels?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

OCULAR INSPECTION CHECKLIST

Where description is indicated, attach additional pages of notes and photographs keyed to appropriate checklist item.

D. EXTERIOR BUILDING INSPECTION (continued)

- | | | YES | NO | N/A |
|--|-------------------------------------|-------------------------------------|--------------------------|-----|
| 24. Attached or abutting improvements: (if yes, provide description and photos) | | | | |
| a. Collapse, partial collapse, or separation of attached porches, carports, Gazebos, or awnings? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| b. Evidence of recent settlement or displacement of exterior steps, patios, or walkways relative to the building? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| c. Signs of movement between building floor and/ or exterior hardscape or retaining wall along the uphill side of hon steeply sloping sites? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| d. Toppling, shifting, or damage/leakage at refrigerant and electrical lines of air conditioning condenser unit(s)? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| 25. Independent exterior improvements: (if yes, provide description and photos) | | | | |
| a. Damaged detached gazebo? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| b. Damage to fences / privacy walls? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| c. Damage to retaining walls? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| d. Damage to walkway? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| e. Evidence of leakage from water supply lines? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| f. Toppling, shifting, or damage/leakage at fuel connection of propane tanks? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| g. Others damage | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | |

E. INTERIOR INSPECTION

26. General information

- | | |
|--|---|
| a. If interior access not possible, identify reason | b. Typical wall and ceiling finish |
| <input type="checkbox"/> i. Red tag | <input type="checkbox"/> i. Drywall |
| <input type="checkbox"/> ii. Hazardous materials | <input type="checkbox"/> ii. Plaster on gypsum lath |
| <input type="checkbox"/> iii. Other hazardous condition,
describe _____ | <input type="checkbox"/> iii. Plaster on wood lath |
| | <input checked="" type="checkbox"/> iv. Other, describe _____ |
| <input checked="" type="checkbox"/> iv. Other, describe _____ | |

OCULAR INSPECTION CHECKLIST

Where description is indicated, attach additional pages of notes and photographs keyed to appropriate checklist item.

E. INTERIOR INSPECTION (continued)

	YES	NO	N/A
27. Walls: (if yes, provide description and photos)			
a. Fresh cracking, buckling, spalling, or detachment of interior wall finish at corners of door and window openings?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
b. Fresh cracking of wall finishes at wall corners or wall/ceiling intersections?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
c. Door or window openings racked out of square?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
d. Wall leaning?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
e. Pattern of cracking that extends from the floor slab through the wall?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
f. Movement or sliding of walls relative to the floor?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
g. Severe cracking, separations, or offsets at building irregularities?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
h. Doors damaged, difficult to operate, or inoperable?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
i. Windows damaged, difficult to operate, or inoperable?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
28. Ceilings: (if yes, provide description and photos)			
a. Collapse of ceiling finish?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
b. Fresh cracking of ceiling finishes, especially at re-entrant corners; cracks along corner bead at stairwell openings; cracking or tearing of finishes at ceiling/wall juncture; or multiple "nail pops"?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
c. Damage to ceiling finishes in vicinity of corridors or commons places?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
d. Separations or cracks in ceiling finishes at split-levels, re-entrant corners, additions, appendages, or other building discontinuities?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
e. Water damage or evidence of recent leakage from plumbing lines or roofing?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

OCULAR INSPECTION CHECKLIST

Where description is indicated, attach additional pages of notes and photographs keyed to appropriate checklist item.

E. INTERIOR INSPECTION (continued)

		YES	NO	N/A
29.	Floors: (if yes, provide description and photos)			
a.	Evidence of recent sloping, sagging, settlement or displacement of floors?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
b.	In slab-on-grade locations, fresh cracking of floor slab or floor finishes?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
c.	Significant sagging or unusual bounciness of floors frames?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
d.	Separations or cracks in floor finishes at split-levels, re-entrant corners, additions, appendages, or other building discontinuities?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
e.	Signs of movement between floor and exterior hardscape or retaining wall along the uphill side of homes on steeply sloping sites?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
f.	A pattern of fresh cracks, gaps, or joint separations in floor finishes?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
g.	Impact damage to floor finishes from falling contents?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
30.	Mechanical systems: (if yes, provide description and photos)			
a.	Displaced connection of appliance flues connected to chimneys?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
b.	Toppling, shifting, leakage from tank, leakage from water connections displaced flue connection or damage/leakage at gas line or electrical connection of water heater?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
c.	Shifting, damage/leakage at gas line, flue connection, electrical connection, refrigerant line, and condensate drain connection of furnace or air conditioning fan-coil unit?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
d.	Damage to gas line of gas stoves or gas fueled clothes dryers?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
e.	Damage to toilets?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
f.	Decreased or restricted water pressure at appliances, faucets, or toilets?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
g.	Toppling or shifting of free-standing wood stove and/or flue?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
h.	Toppling, shifting, damage/leakage at fuel connection of fuel oil tank?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
i.	Other Damage in the dining room	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
j.	Damage near the gas tank	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

OCULAR INSPECTION CHECKLIST

Where description is indicated, attach additional pages of notes and photographs keyed to appropriate checklist item.

E. INTERIOR INSPECTION (continued)

- | | | | |
|---|--------------------------|-------------------------------------|--------------------------|
| 31. Architectural woodwork and special finishes: (if yes, provide description and photos) | YES | NO | N/A |
| a. Shifting of or damage to kitchen or bathroom cabinetry? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| b. Impact damage to countertops from falling objects? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| c. Cracking of ceramic tile in showers or tub/shower enclosures consistent with
earthquake damage to adjacent wall finishes? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |

F. CONTINGENT INSPECTIONS

- | | | | |
|--|--------------------------|-------------------------------------|--------------------------|
| 32. Retaining Tank Wall damage? | YES | NO | N/A |
| 33. Water tank or other field subterranean structure | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |

OCULAR INSPECTION CHECKLIST

ANEXO A

Nombre de la Escuela: Juana Sánchez González
Código de la Escuela: 30734

Fecha de Inspección: 14 de enero 2020
Nombre de Inspector: Carlos N Rivera Rodriguez P. E

Comentarios:

No se observaron daños en los elementos estructurales relacionados a los eventos sísmicos a la fecha de la inspección. No obstante, es necesario hacer ciertas reparaciones que no están relacionadas a los eventos sísmicos, es necesario la reparación de estas por la preservación de la estructura.

Edificio 1 - Salones de clase. No se observó daño a los elementos estructurales. Se debe reparar grieta que se observa de junta fría debido a la construcción de baños. Se ve en la misma unión de la estructura vieja con la nueva. Nos informan que esa grieta ya era existente.

Edificio 2 – Salones de clase. No se observan daños en los elementos estructurales.

Edificio 3 - Comedor, biblioteca, oficinas administrativas y baños. No tuvimos acceso al comedor, pero no se observan daños exteriores y tampoco hay olor a gas. Se evaluó por exterior.

Edificio 4 - Salones de clase. No se observan daños en los elementos estructurales.

Edificio 5 - Salones de clase. No tuvimos acceso a este edificio, pero exteriormente no se observan daños.

Edificio 6 - Salones de clase. No se observan daños en los elementos estructurales. Dos de los salones no tuvimos acceso, pero se observaron exteriormente no se observan daños.

Cancha - No se observan daños en los elementos estructurales.

OCULAR INSPECTION CHECKLIST

ANEJO A (cont.)

Plano de Sitio	Juana Sánchez González
Descripción:	Vista aérea de la escuela / Plano de planta de escuela para identificar las áreas evaluadas.

The diagram illustrates the layout of a school building. On the left, there is a two-story wing labeled 'Aulas' containing 'Salón #11' and 'Salón #10'. Above this, a single room is labeled 'Salón #4'. To the right of 'Salón #11' is a row of five classrooms labeled 'Salón #5', 'Salón #6', 'Salón #7', 'Salón #8', and 'Salón #9'. Below 'Salón #11' is a room labeled 'T.S.'. A 'Glorieta' (courtyard) is located between the 'Aulas' wing and the main entrance area. The main entrance leads into a large room labeled 'Baños' (Bathrooms). To the right of the entrance is an 'Oficina' (Office) and a 'Biblioteca' (Library). Further to the right is a 'Comedor' (Dining Hall). At the far right end of the building is a room labeled 'Parque K Kinder #12'. Red arrows indicate potential inspection routes or paths between rooms, while green arrows indicate other routes or perhaps specific points of interest. A red double-headed arrow is positioned above the 'Parque K Kinder #12' room.


OCULAR INSPECTION CHECKLIST

ANEJO A (cont.)

Edificio:	1	
Descripción:	Junta fría de los baños nuevos adjunto a la estructura. Se recomienda reforzar empañetado y reparar por la preservación del edificio.	
Edificio:	1	
Descripción:	Junta fría de los baños nuevos adjunto a la estructura.	
Edificio:	1	
Descripción:	Techo del área de los baños, muestra que es una estructura añadida.	
Edificio:	2	
Descripción:	No se observaron daños estructurales.	

OCULAR INSPECTION CHECKLIST

ANEJO A (cont.)

Edificio:	2		
Descripción:	No se observaron daños estructurales.		
Edificio:	3		
Descripción:	No se observaron daños estructurales.		
Edificio:	3		
Descripción:	No se observaron daños estructurales.		
Edificio:	4		
Descripción:	No se observaron daños estructurales.		

OCULAR INSPECTION CHECKLIST

ANEJO A (cont.)

Edificio:	5		
Descripción:	No se observaron daños estructurales.		
Edificio:	6		
Descripción:	No se observaron daños estructurales. No hubo acceso al interior, se inspecciono por el exterior.		
Edificio:	7		
Descripción:	No se observaron daños estructurales. No hubo acceso a un salón y una oficina.		
Edificio:	7		
Descripción:	No se observaron daños Se observo el exterior del edificio.		
Edificio:	Cancha		
Descripción:	No se observaron daños estructurales.		

OCULAR INSPECTION CHECKLIST

G. RECOMENDACIÓN AL SECRETARIO

Departamento de Educación
Dr. Eligio Hernández Pérez
Secretario de Educación

Hora de Entrada a Inspección:	1:15 pm	Hora de Salida de Inspección:	3:45pm
Escuela:	Juana Sanchez	Código:	30734
Municipio:	Juncos	Fecha de Inspección:	14 de enero 2020

- Abrir Escuela (Verde)
- Abrir Parcialmente la Escuela (Amarillo)
- No Abrir la Escuela (Rojo)

Comentarios:

No Hubo Acceso al interior del Comedor , Edificio 5(Almacen y Salon) y Edificio 6 (Salon TS , Salon 3) no habia llaves de candados. Se inspecciono exteriormente.
No se observaron daños a causa de los eventos sismicos al momento de la inspeccion.
Se observaron algunas deficiencias generales que no estan relacionadas a los eventos sismicos.

Ver anexo A adjunto para mas detalles.

Se debe entender que este informe está basado solamente en una inspección ocular de las facilidades con el propósito de observar en las escuelas la presencia de daños significativos causados por los eventos sísmicos registrados hasta la fecha de este informe. La determinación de la adecuación estructural de las escuelas y su cumplimiento con los códigos aplicables de diseño o construcción, al igual que el desarrollo de recomendaciones para la rehabilitación de las facilidades, requerirá una evaluación detallada.

Carlos N Rivera Rodriguez
Preparado por: Nombre (Letra de Molde)



19489
Licencia

Sello

Víctor M. Rodríguez
Revisado por: Nombre (Letra de Molde)

OCULAR INSPECTION CHECKLIST

G. RECOMENDACIÓN AL SECRETARIO

Departamento de Educación
Dr. Eligio Hernández Pérez
Secretario de Educación

Hora de Entrada
a Inspección: 1:15 pm

Hora de Salida de
Inspección: 3:45 pm

Escuela: Juana Sánchez González

Código: 30734

Municipio: Juncos

Fecha de Inspección: 1/10/2020

Abrir Escuela (Verde)

Abrir Parcialmente la Escuela (Amarillo)

No Abrir la Escuela (Rojo)

Comentarios:

Disclaimer:

It should be noted that, as requested, this report is based solely on a visual inspection of the as-is facility for the purpose of assessing the presence of significant structural damage resulting from the seismic event of January 07, 2020 which may affect its structural condition compared to that prior to the seismic event.

The determination of the structural adequacy of the existing facility to meet the applicable design and construction building codes requirements as well as developing recommendations for the rehabilitation of the facility will require a more extensive investigation than that one requested to be conducted and reported herein.

Rafael Pozo Montás
Nombre (Letra de Molde)



Firma

10028
Licencia



Fecha de Expiración: 2024-09-30