

## GENERAL EARTHQUAKE DAMAGE INSPECTION CHECKLIST

**G. RECOMENDACIÓN AL SECRETARIO**

Departamento de Educación  
Dr. Eligio Hernández Pérez  
Secretario de Educación

Hora: 9:30 AM

Código:

Escuela: Bernardo Gonzalez Colon

Fecha de  
Inspección:

January 10, 2020

Municipio: Utuado

Abrir Escuela (Verde)

☒

Exclude rooms #7 and #13.

Abrir Parcialmente la Escuela (Amarillo)

☐

No Abrir la Escuela (Rojo)

☐

Comentarios:

Concrete columns 1 ft \* 1.5 ft section with 11 ft span. Beams section 1 ft\* 1.5ft. The classroom #2 in first floor North Building can't inspected because no key to open the room. The classroom over it, at the second level no have any condition to report.

School rooms #7 and # 13 with existing cracks before earthquake, in first and second floors slab. Hair cracks in the center beam at first floor roof. To be evaluate original construction plans and the concrete compression. Recommended no use this two rooms class until complete the structural evaluation. The recommendation is precautionary measure that should not be interpreted as a deficiency until the analysis be completed. See pictures attached.

One lamp cover 16 in\* 4 ft in room # 28 came off and broken in the floor. Some lamps cover in other room are not fixed and need to fix it. The PBA Arecibo Region that were present in the inspection, sended employees to repair it.

Adolfo Bonilla Rodriguez  
Nombre (Letra de Molde)

Firma

10088  
# Licencia



## GENERAL EARTHQUAKE DAMAGE INSPECTION CHECKLIST

Where description is indicated, attach additional pages of notes and photographs keyed to appropriate checklist item.

**A. GENERAL INFORMATION**

1. Street Address of the School: PR 123 km. 56.3  
 City: Utua State: Puerto Rico Zip: 00641
2. School Name: Bernardo Gonzalez Colon
3. Date of inspection: Friday 10, 2020
4. Inspector's Name: Adolfo Bonilla Rodriguez, P.E., R.P.A. - Lic. 10088

**B. BUILDING SITE INSPECTION**

## 5. Utility Service Safety:

IMPORTANT—Immediately following an earthquake, check the entire property, especially near appliances, for the smell of gas. If gas odor is detected, turn off the gas at the meter where it enters the house. Locate and repair leaks before turning gas back on. If the gas odor persists after the gas has been shut off, vacate the building and contact the gas utility company immediately.

IMPORTANT—Before entering a damaged, vacant building verify that gas is off. Check the gas meter for damage and position of main gas valve, either a manual valve or a seismically-activated gas shut-off valve. Do not enter the building if gas odor is detected.

- a. Odor of natural gas leakage? ☐ YES ☒ NO      b. Downed powerlines? ☐ YES ☒ NO

## 6. Surrounding topography: (check one)

- ☐ Flat  
☒ Gently sloping (easily walkable)  
☐ Steeply sloping (difficult or impossible to walk in some areas)

## 7. Building pad: (check one)

- ☒ Flat  
☐ Terraced or multilevel  
☐ Gently sloping (less than 4-foot ground surface elevation difference across house)  
☐ Steeply sloping (greater than 4-foot ground surface elevation difference across house)

## 8. Geotechnical Issues: (if yes, provide description and photos)

- |   | YES                      | NO                                  |
|---|--------------------------|-------------------------------------|
| a. New cracks in the ground?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| b. Signs of fresh cracking in or movement of hardscape?   | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| c. Signs of fresh cracking in or movement of retaining walls?                                     | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| d. Patterns of cracking that extend through the ground surface, hardscape, and improvements?      | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| e. Evidence of sand boils or other fresh-appearing deposits of sand or mud?                       | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| f. Unusual slumping, rising, or bulging of the ground surface?                                    | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| g. Evidence of rock falls or slope instability above site?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| h. Ground movement or wet areas indicating possible broken underground utility lines?             | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| i. Other phenomena (e.g., septic tanks surfacing, differential settlement, ground consolidation)? | <input type="checkbox"/> | <input checked="" type="checkbox"/> |

# GENERAL EARTHQUAKE DAMAGE INSPECTION CHECKLIST

Where description is indicated, attach additional pages of notes and photographs keyed to appropriate checklist item.

## B. BUILDING SITE INSPECTION (continued)

YES NO

9. Evidence of earthquake-induced permanent ground deformation in the immediate vicinity of the property? ☐ YES ☒ NO

## C. GENERAL BUILDING INFORMATION

10. Safety Assessment Tag: (check one) ☒ None ☐ Green ☐ Yellow ☐ Red

(others): ☐ Yellow ☐ Red

11. a) Year of original construction (best estimate): 1972 - Inauguration 1975

b) Total square footage (best estimate): 19600 school 7700 basketball court  
(two story building 39200 sq.ft.)

YES NO

12. Have any repairs, modifications, or demolition been performed since the earthquake? ☐ YES ☒ NO

If yes, describe \_\_\_\_\_

13. Building configuration:

- ☐ a. Single story  
☐ b. Combination one and two story  
☒ c. Full two story  
☐ d. Three story  
☐ e. Split level  
☐ f. Typical  
☐ g. Other, describe \_\_\_\_\_

16. Sill bolting:

- ☐ a. Structure bolted to foundation  
☐ b. Structure not bolted to foundation  
☒ c. Don't know Presume not bolted

14. Exterior wall finish:

- ☐ a. Stucco  
☐ b. Panel siding  
☐ c. Metal siding  
☐ d. Masonry veneer  
☒ e. Other, describe Cement Plaster

17. Roof configuration:

- ☐ a. Gable  
☐ b. Hip  
☒ c. Flat or very low slope  
☐ d. Shed  
☐ e. Other, describe \_\_\_\_\_

15. Foundation configuration:

- ☐ a. Slab-on-grade  
☐ b. Crawlspac without cripple walls  
☐ c. Crawlspac with cripple walls  
☐ d. Exposed piers or posts  
☒ e. Typical Beam and columns (Portico)  
☐ f. Metal  
☐ g. Other, describe \_\_\_\_\_

18. Roof covering:

- ☐ a. Asphaltic membrane  
☐ b. Wood shingle or shake  
☒ c. Concrete  
☐ d. Metal  
☐ e. Elastomeric  
☐ f. Other, describe \_\_\_\_\_

# GENERAL EARTHQUAKE DAMAGE INSPECTION CHECKLIST

Where description is indicated, attach additional pages of notes and photographs keyed to appropriate checklist item.

## D. EXTERIOR BUILDING INSPECTION

|   | YES                      | NO                                  | N/A                                 |
|---|--------------------------|-------------------------------------|-------------------------------------|
| <b>19. General: (if yes, provide description and photos)</b>  |                          |                                     |                                     |
| a. Collapse, partial collapse, or building off foundation?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> |                                     |
| b. Obvious lean in any story?   | <input type="checkbox"/> | <input checked="" type="checkbox"/> |                                     |
| <b>20. Exterior walls: (if yes, provide description and photos)</b>   |                          |                                     |                                     |
| a. Fresh cracking at corners of door and window openings?   | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| b. Fresh cracking at building corners?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| c. Door or window openings racked out of square?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| d. Broken glass in windows or doors?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| e. Wall leaning?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| f. Bulging or delamination of stucco?   | <input type="checkbox"/> | <input checked="" type="checkbox"/> |                                     |
| g. Pattern of cracking that extends from the ground surface, through foundation, and wall?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> |                                     |
| h. Evidence of recent relative movement at mudsill line?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> |                                     |
| i. At locations where the exterior stucco is continuous from the framing down over the foundation, is there cracking of stucco along the mudsill level accompanied by indications of permanent displacement (sliding) of the building relative to the foundation? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| j. Collapse, partial collapse, or separation of masonry veneer?   | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| k. Severe cracking, separations, or offsets at building irregularities?   | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| <b>21. Foundation: (if yes, provide description and photos)</b>   |                          |                                     |                                     |
| a. Fresh cracking of exposed perimeter foundation?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> |                                     |
| b. Relative movement between slab and footing in "two-pour" slab-on-grade foundations?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| c. Ask homeowner if any earthquake retrofits have been done to the home?  | <input type="checkbox"/> | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| If Y describe: _____  |                          |                                     |                                     |
| d. If the answer to c is Y, were bolts added to connect the home to the foundation?   | <input type="checkbox"/> | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| e. If the answer to c is Y, were plywood or sheathing added to any cripple walls under the home?  | <input type="checkbox"/> | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |

# GENERAL EARTHQUAKE DAMAGE INSPECTION CHECKLIST

Where description is indicated, attach additional pages of notes and photographs keyed to appropriate checklist item.

## D. EXTERIOR BUILDING INSPECTION (continued)

| 22. Kitchen Hook (if yes, provide description and photos)   | YES                      | NO                                  | N/A                                 |
|---|--------------------------|-------------------------------------|-------------------------------------|
| a. Present on external wall?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| b. Present at internal location?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| c. Collapse or partial collapse?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| d. Visible damage or cracking?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> |                                     |
| e. Visible tilting or separation from building?   | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| f. Shifted or loose and displaced   | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| g. Deterioration or deformation   | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
|   | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| 23. Roof: (if yes, provide description and photos)  |                          |                                     |                                     |
| a. Shifted or dislodged or concrete damage?   | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| b. Impact damage to roof from falling object?   | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| c. Displaced rooftop HVAC units?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| d. Significantly sagging roof ridgelines?   | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| e. Signs of movement between rafter tails and wall finishes at eaves?   | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| f. Buckled/dislodged flashing or tearing of roof membrane, roof/wall intersections in split level buildings, additions, or other building irregularities? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| g. Tearing of roof membrane or deck waterproofing at re-entrant corners?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| h. Toppling, shifting, or damage/leakage at refrigerant and electrical lines of rooftop mechanical equipment?   | <input type="checkbox"/> | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| i. Shifting of or damage to solar panels?   | <input type="checkbox"/> | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |

## GENERAL EARTHQUAKE DAMAGE INSPECTION CHECKLIST

Where description is indicated, attach additional pages of notes and photographs keyed to appropriate checklist item.

### D. EXTERIOR BUILDING INSPECTION (continued)

- |  | YES                      | NO                                  | N/A                      |
|--|--------------------------|-------------------------------------|--------------------------|
| <b>24. Attached or abutting improvements: (if yes, provide description and photos)</b>   |                          |                                     |                          |
| a. Collapse, partial collapse, or separation of attached porches, carports, Gazebos, or awnings?   | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| b. Evidence of recent settlement or displacement of exterior steps, patios, or walkways relative to the building?                            | <input type="checkbox"/> | <input checked="" type="checkbox"/> |                          |
| c. Signs of movement between building floor and/ or exterior hardscape or retaining wall along the uphill side of non steeply sloping sites? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| d. Toppling, shifting, or damage/leakage at refrigerant and electrical lines of air conditioning condenser unit(s)?                          | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Note: No electrical services at the date of inspection   |                          |                                     |                          |
| <b>25. Independent exterior improvements: (if yes, provide description and photos)</b>   |                          |                                     |                          |
| a. Damaged detached gazebo?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| b. Damage to fences / privacy walls?   | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| c. Damage to retaining walls?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| d. Damage to walkway?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| e. Evidence of leakage from water supply lines?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| f. Toppling, shifting, or damage/leakage at fuel connection of propane tanks?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| g. Others damage   | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |

Note: A 4 ft tall concrete block closet under the EAST stairs show an existing cracks in the joint of stair slab and block wall. The construction was do it after the school construction and is a condition of thin cement plaster application.

### E. INTERIOR INSPECTION N/A

#### 26. General information

a. If interior access not possible, identify reason

- ☐ i. Red tag
- ☐ ii. Hazardous materials
- ☐ iii. Other hazardous condition, describe \_\_\_\_\_
- ☐ iv. Other, describe \_\_\_\_\_

b. Typical wall and ceiling finish

- ☐ i. Drywall
- ☐ ii. Plaster on gypsum lath
- ☐ iii. Plaster on wood lath
- ☐ iv. Other, describe \_\_\_\_\_



# GENERAL EARTHQUAKE DAMAGE INSPECTION CHECKLIST

Where description is indicated, attach additional pages of notes and photographs keyed to appropriate checklist item.

## E. INTERIOR INSPECTION (continued)

| 27. Walls: (if yes, provide description and photos)   | YES                      | NO                                  | N/A                      |
|---|--------------------------|-------------------------------------|--------------------------|
| a. Fresh cracking, buckling, spalling, or detachment of interior wall finish at corners of door and window openings?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| b. Fresh cracking of wall finishes at wall corners or wall/ceiling intersections?   | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| c. Door or window openings racked out of square?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| d. Wall leaning?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| e. Pattern of cracking that extends from the floor slab through the wall?   | <input type="checkbox"/> | <input checked="" type="checkbox"/> |                          |
| Note: Existing cracks previous earthquake in classrooms #7 and #13. See reports attach.   |                          |                                     |                          |
| f. Movement or sliding of walls relative to the floor?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> |                          |
| g. Severe cracking, separations, or offsets at building irregularities?   | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| h. Doors damaged, difficult to operate, or inoperable?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| i. Windows damaged, difficult to operate, or inoperable?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| <br>  |                          |                                     |                          |
| 28. Ceilings: (if yes, provide description and photos)  | YES                      | NO                                  | N/A                      |
| a. Collapse of ceiling finish?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| b. Fresh cracking of ceiling finishes, especially at re-entrant corners; cracks along corner bead at stairwell openings; cracking or tearing of finishes at ceiling/wall juncture; or multiple "nail pops"? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| c. Damage to ceiling finishes in vicinity of corridors or commons places?   | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| d. Separations or cracks in ceiling finishes at split-levels, re-entrant corners, additions, appendages, or other building discontinuities?   | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| e. Water damage or evidence of recent leakage from plumbing lines or roofing?   | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |

Note: One lamp cover 16 in\* 4 ft in room # 28 came off and broken in the floor. Some lamps cover in other room are not fixed and need to fix it. The PBA Arecibo Region that were present in the inspection, sended employees to repair it.

# GENERAL EARTHQUAKE DAMAGE INSPECTION CHECKLIST

Where description is indicated, attach additional pages of notes and photographs keyed to appropriate checklist item.

## E. INTERIOR INSPECTION (continued)

| 29. Floors: (if yes, provide description and photos)  | YES                      | NO                                  | N/A                                 |
|---|--------------------------|-------------------------------------|-------------------------------------|
| a. Evidence of recent sloping, sagging, settlement or displacement of floors?   | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| b. In slab-on-grade locations, fresh cracking of floor slab or floor finishes?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| c. Significant sagging or unusual bounciness of floors frames?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| d. Separations or cracks in floor finishes at split-levels, re-entrant corners, additions, appendages, or other building discontinuities?   | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| e. Signs of movement between floor and exterior hardscape or retaining wall along the uphill side of homes on steeply sloping sites?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| f. A pattern of fresh cracks, gaps, or joint separations in floor finishes?   | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| g. Impact damage to floor finishes from falling contents?   | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| 30. Mechanical systems: (if yes, provide description and photos)  | <input type="checkbox"/> | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| a. Displaced connection of appliance flues connected to chimneys?   | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| b. Toppling, shifting, leakage from tank, leakage from water connections displaced flue connection or damage/leakage at gas line or electrical connection of water heater?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| c. Shifting, damage/leakage at gas line, flue connection, electrical connection, refrigerant line, and condensate drain connection of furnace or air conditioning fan-coil unit?<br>Note: No electrical service at inspection date. | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| d. Damage to gas line of gas stoves or gas fueled clothes dryers?   | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| e. Damage to toilets?   | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| f. Decreased or restricted water pressure at appliances, faucets, or toilets?   | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| g. Toppling or shifting of free-standing wood stove and/or flue?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| h. Toppling, shifting, damage/leakage at fuel connection of fuel oil tank?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| i. Other Damage in the dining room  | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| j. Damage near the gas tank   | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |



## GENERAL EARTHQUAKE DAMAGE INSPECTION CHECKLIST

Where description is indicated, attach additional pages of notes and photographs keyed to appropriate checklist item.

### E. INTERIOR INSPECTION (continued)

- |  | YES                      | NO                                  | N/A                      |
|--|--------------------------|-------------------------------------|--------------------------|
| 31. Architectural woodwork and special finishes: (if yes, provide description and photos)                                    |                          |                                     |                          |
| a. Shifting of or damage to kitchen or bathroom cabinetry?   | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| b. Impact damage to countertops from falling objects?  | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| c. Cracking of ceramic tile in showers or tub/shower enclosures consistent with earthquake damage to adjacent wall finishes? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |

### F. CONTINGENT INSPECTIONS

- |  | YES                      | NO                       | N/A                                 |
|--|--------------------------|--------------------------|-------------------------------------|
| 32. Retaining Tank Wall damage?                      | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 33. Water tank or other field subterranean structure | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |