

Facility Evaluation (Site) Form for: Jose D Rosado |Codigo: 71787

Inspector(s) Name:

Inspection Date:

Mon Oct 23 2017

Inspection Time:

12:30:00 GMT-0500 (Central Daylight Time)

Type of Facility:

escuela

School Name:

Jose D Rosado

School Code:

71787

Latitude:

18.41536202

Longitude:

-66.35873177

Building Contact:

Number of Buildings:

General:

- Facility Area Flooded: **No**
- One or More Buildings Flooded: **No**
- Other Water Damage in Facility: **No**

Comments:

Services:

- Potable Water Service: **Yes**
- Potable Water Cistern: **Yes**
- Sewer Service: **No**
- Septic Tank Available: **Yes**
- Electrical Power Service: **No**
- Generator Available: **No**
- Gas (LP) Storage Tank Intact: **Yes**

Comments:

Class Room Ventilation:

- Adequate Classroom Ventilation: **Yes**

- AC System Operating: **No**

Comments:

Access:

- Safe Access to Buildings: **Yes**

Comments:

Perimeter Fences/Walls:

- Damage to Perimeter or Fence: **Minor/None**
- Damage to Retaining Wall or Slope: **Minor/None**

Comments:

Overall Areas:

- Recreation Area Damage: **Minor/None**
- Parking Area Damage: **Minor/None**
- Falling Hazards in Play Areas: **Minor/None**
- Standing Water in Play Areas: **Minor/None**
- Debris or Tree Hazards: **Minor/None**
- Electrical or Power Line Hazards: **Moderate**

Comments:

Has a broken power pole.

Lunch Room:

- Cooking Equipment: **Yes**
- Refrigerated or Dry Food Storage: **Yes**
- Operational Exhaust Fan: **Yes**
- Fire Suppression System: **Yes**
- Screens: **Yes**

Comments:

Buildings:

Comments:

Additional Comments:

Findings:

1. There is a broken power pole.
-

Recommendations:

1. Barricade the area and substitute the power pole.
-