

Facility Evaluation (Site) Form for: Elisa Davila Vazquez |Codigo: 71795

Inspector(s) Name:

SJ-07

Inspection Date:

Mon Oct 23 2017

Inspection Time:

06:55:56 GMT-0500 (Central Daylight Time)

Type of Facility:

escuela

School Name:

Elisa Davila Vazquez

School Code:

71795

Latitude:

18.4006618

Longitude:

-66.30625425

Building Contact:**Number of Buildings:**

General:

- Facility Area Flooded: **No**
- One or More Buildings Flooded: **No**
- Other Water Damage in Facility: **No**

Comments:

Services:

- Potable Water Service: **No**
- Potable Water Cistern: **No**
- Sewer Service: **No**
- Septic Tank Available: **Yes**
- Electrical Power Service: **No**
- Generator Available: **No**
- Gas (LP) Storage Tank Intact: **Yes**

Comments:

One of the cistern was stolen; the other one is broken.

Class Room Ventilation:

- Adequate Classroom Ventilation: **Yes**
- AC System Operating: **No**

Comments:

Access:

- Safe Access to Buildings: **Yes**

Comments:

Perimeter Fences/Walls:

- Damage to Perimeter or Fence: **Minor/None**
- Damage to Retaining Wall or Slope: **Minor/None**

Comments:

Barricades needed in lateral patio; between building 2 and 3.

Overall Areas:

- Recreation Area Damage: **Minor/None**
- Parking Area Damage: **Minor/None**
- Falling Hazards in Play Areas: **Minor/None**
- Standing Water in Play Areas: **Minor/None**
- Debris or Tree Hazards: **Minor/None**
- Electrical or Power Line Hazards: **Minor/None**

Comments:

Lunch Room:

- Cooking Equipment: **Yes**
- Refrigerated or Dry Food Storage: **Yes**
- Operational Exhaust Fan: **No**
- Fire Suppression System: **No**
- Screens: **Yes**

Comments:

The gas tanks need to be revised.

Buildings:

- Building 1: **Green - Inspected**
- Building 2: **Green - Inspected**
- Building 3: **Green - Inspected**

Comments:

Recommended evaluation of an electrical engineer in building 3. Building 1: 1st floor lunch room, classroom, office; building

Recommendation: evaluation of an electrical engineer in building of building 1: no need; kitchen room; classroom; office; building

2: library and classroom; building 3: classrooms; one basketball court and 2 wood structures.

Additional Comments:

Findings:

1. No water service. 2. Broken cistern. 3. Check gas tank (possible gas leak). 4. Power box under water.

Recommendations:

1. Repair or replace cistern. 2. Check gas tank for leaks. 4. Electrical engineering evaluation is required.
