

# Facility Evaluation (Site) Form for: Rosa M Rodriguez |Codigo: 72033

---

**Inspector(s) Name:**

SJ-11

**Inspection Date:**

Mon Oct 23 2017

**Inspection Time:**

07:10:44 GMT-0500 (Central Daylight Time)

**Type of Facility:**

escuela

**School Name:**

Rosa M Rodriguez

**School Code:**

72033

**Latitude:**

18.48060075

**Longitude:**

-66.41188286

**Building Contact:****Number of Buildings:**

---

**General:**

- Facility Area Flooded: **No**
- One or More Buildings Flooded: **No**
- Other Water Damage in Facility: **Yes**

**Comments:**

Repair classroom door on bldg 1. Ceiling water infiltration.

---

**Services:**

- Potable Water Service: **Yes**
- Potable Water Cistern: **Yes**
- Sewer Service: **No**
- Septic Tank Available: **Yes**
- Electrical Power Service: **No**
- Generator Available: **No**
- Gas (LP) Storage Tank Intact: **Yes**

**Comments:**

Potable water comes and goes

---

## Class Room Ventilation:

- Adequate Classroom Ventilation: **Yes**
- AC System Operating: **No**

### Comments:

---

## Access:

- Safe Access to Buildings: **Yes**

### Comments:

---

## Perimeter Fences/Walls:

- Damage to Perimeter or Fence: **Moderate**
- Damage to Retaining Wall or Slope: **Minor/None**

### Comments:

Repaired fence near entrance. A falling tree is over the fence.

---

## Overall Areas:

- Recreation Area Damage: **Minor/None**
- Parking Area Damage: **Minor/None**
- Falling Hazards in Play Areas: **Minor/None**
- Standing Water in Play Areas: **Minor/None**
- Debris or Tree Hazards: **Moderate**
- Electrical or Power Line Hazards: **Minor/None**

### Comments:

A falling tree near entrance

---

## Lunch Room:

- Cooking Equipment: **Yes**
- Refrigerated or Dry Food Storage: **Yes**
- Operational Exhaust Fan: **No**
- Fire Suppression System: **Yes**
- Screens: **Yes**

### Comments:

Exhaust fan is not available. Provide.

---

## Buildings:

- Building 1: **Yellow - Restricted Use**
- Building 2: **Green - Inspected**

- Building 3: **Green - Inspected**

**Comments:**

On bldg 1 two door are missing. A/c tip over.

---

**Additional Comments:**

---

**Findings:**

1. Building 1: two classroom doors are missing (torn). 2. Fallen tree on fence.

---

**Recommendations:**

1. Building 1: do not use classrooms until doors are replaced. 2. Barricade area where tree fell.

---