

Facility Evaluation (Site) Form for: Angel G. Quintero | Codigo: 17186

Inspector(s) Name:

SJ-04

Inspection Date:

Tue Oct 24 2017

Inspection Time:

07:30:00 GMT-0500 (Central Daylight Time)

Type of Facility:

escuela

School Name:

Angel G. Quintero

School Code:

17186

Latitude:

18.35816

Longitude:

-66.44574979

Building Contact:**Number of Buildings:**

General:

- Facility Area Flooded: **No**
- One or More Buildings Flooded: **No**
- Other Water Damage in Facility: **Yes**

Comments:

Services:

- Potable Water Service: **No**
- Potable Water Cistern: **Yes**
- Sewer Service: **Yes**
- Septic Tank Available: **No**
- Electrical Power Service: **No**
- Generator Available: **No**
- Gas (LP) Storage Tank Intact: **Yes**

Comments:

Class Room Ventilation:

- Adequate Classroom Ventilation: **Yes**
- AC System Operating: **No**

Comments:

1 AC unit damaged

Access:

- Safe Access to Buildings: **No**

Comments:

Down electrical lines along roadway. Water damaged to ceiling and walls in classroom

Perimeter Fences/Walls:

- Damage to Perimeter or Fence: **Moderate**
- Damage to Retaining Wall or Slope: **Minor/None**

Comments:

Perimeter fence has fallen trees on it.

Overall Areas:

- Recreation Area Damage: **Minor/None**
- Parking Area Damage: **Minor/None**
- Falling Hazards in Play Areas: **Minor/None**
- Standing Water in Play Areas: **Minor/None**
- Debris or Tree Hazards: **Moderate**
- Electrical or Power Line Hazards: **Minor/None**

Comments:

18 Light Fixtures damaged. Exterior wall paint is peeling off. Water leaks in classroom S 207-01. Recreational Area gutters and side panels are off.

Lunch Room:

- Cooking Equipment: **Yes**
- Refrigerated or Dry Food Storage: **Yes**
- Operational Exhaust Fan: **Yes**
- Fire Suppression System: **Yes**
- Screens: **Yes**

Comments:

Buildings:

- Building 1: **Green - Inspected**
- Building 2: **Green - Inspected**

- Building 3: **Green - Inspected**

Comments:

Barricade the backyard over behind the school due to debris. Building 1 estimated damaged 0 to 1%. Building 2 estimated damage 0 to 1%. Building 3 estimated damage 0 to 1%. Building 3 is in good condition to be used but needs to be follow up by a struct. engineer.

Additional Comments:

Findings:

1.Barricade the backyard over behind the school due to debris. 2.Building 1 estimated damaged 0 to 1%. 3.Building 2 estimated damage 0 to 1%. 4.Building 3 estimated damage 0 to 1%. 5.Building 3 is in good condition to be used but needs to be follow up by a struct. engineer.

Recommendations:

1. send structural engineer 2.fix damages on bldgs: 1,2 3.clean debris on backyard.
