

# Facility Evaluation (Site) Form for: Su Nicolas Rodriguez | Codigo: 71050

---

**Inspector(s) Name:**

**Inspection Date:**

Thu Oct 19 2017

**Inspection Time:**

08:00:00 GMT-0500 (Central Daylight Time)

**Type of Facility:**

**School Name:**

Su Nicolas Rodriguez

**School Code:**

71050

**Latitude:**

18.32161107

**Longitude:**

-66.34418136

**Building Contact:**

**Number of Buildings:**

---

## General:

- Facility Area Flooded: **Yes**
- One or More Buildings Flooded: **Yes**
- Other Water Damage in Facility: **No**

### Comments:

CLASSROOMS WINDOW

---

## Services:

- Potable Water Service: **Yes**
- Potable Water Cistern: **Yes**
- Sewer Service: **No**
- Septic Tank Available: **No Data**
- Electrical Power Service: **No**
- Generator Available: **No**
- Gas (LP) Storage Tank Intact: **Yes**

### Comments:

NO WATER SERVICES/NEED CISTERN ON HIGH ELEVATION ROOF MISSING 2 CISTERNS/ONLY ONE TANK LEFT

---

## Class Room Ventilation:

- Adequate Classroom Ventilation: **Yes**
- AC System Operating: **No**

**Comments:**

---

**Access:**

- Safe Access to Buildings: **Yes**

**Comments:**

---

**Perimeter Fences/Walls:**

- Damage to Perimeter or Fence: **Moderate**
- Damage to Retaining Wall or Slope: **Minor/None**

**Comments:**

TREE FELL ON FENCE AT LEAST IN ONE PLACE

---

**Overall Areas:**

- Recreation Area Damage: **Minor/None**
- Parking Area Damage: **Minor/None**
- Falling Hazards in Play Areas: **Minor/None**
- Standing Water in Play Areas: **Minor/None**
- Debris or Tree Hazards: **Minor/None**
- Electrical or Power Line Hazards: **Minor/None**

**Comments:**

BETWEEN A FEW BUILDINGS

---

**Lunch Room:**

- Cooking Equipment: **Yes**
- Refrigerated or Dry Food Storage: **No**
- Operational Exhaust Fan: **No**
- Fire Suppression System: **Yes**
- Screens: **Yes**

**Comments:**

NO FOOD EATEN BY REFUGEES/EXTERIOR DUCT BLOWNOFF

---

**Buildings:**

**Comments:**

---

**Additional Comments:**

MINOR DAMAGE TO LOWERED WINDOWS THROUGHOUT

---

**Findings:**

1.No potable water service available, 2.No electrical power available, 3.Moderate damage to perimeter fence, 4.Moderate presence of hazards/debris/trees, 5.Moderate downed power lines or electrical hazards, 6.Roof damage at health room, 7.Storage room door blown off.

---

**Recommendations:**

1.Provide potable water service, 2.Provide electrical power, 3.Replace perimeter fence, 4.Remove debris, 5.Fix downed electrical lines, 6.Fix the storage facilities and the health room roofs.

---